

ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰਬਰ 2 ਭ. ਮ. ਸਾਖਾ ਮੋਗਾ

To,

The Principal,

Bhai Roop Chand Convent School,

Phulle wala road, Samadh Bhai, Distt Moga (Punjab)

ਨੰਬਰ 328

ਮਿਤੀ 28/05/2026

ਵਿਸ਼ਾ:


ਇਮਾਰਤ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਬਾਬਤ 2026-27 ।


ਉਪਰੋਕਤ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਸਬੰਧਤ ਜੂਨੀਅਰ ਇੰਜਨੀਅਰ ਵਲੋਂ ਕੀਤਾ ਗਿਆ । ਬਿਲਡਿੰਗ 2026-27 ਲਈ ਸੁਰੱਖਿਅਤ ਪਾਈ ਗਈ ਹੈ । ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਮਿਤੀ 31-03-2027 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ । ਅੱਗੇ ਤੋਂ ਹੇਠ ਲਿਖੀਆਂ ਹਦਾਇਤਾਂ ਵਲੋਂ ਵਿਸ਼ੇਸ਼ ਧਿਆਨ ਦਿੱਤਾ ਜਾਵੇ ।

- 1) ਬਿਲਡਿੰਗ ਦੇ ਆਲੇ-ਦੁਆਲੇ ਅਤੇ ਛੱਤਾ ਉਪਰ ਪਾਣੀ ਨਾ ਖੜਾ ਹੋਣ ਦਿੱਤਾ ਜਾਵੇ।
- 2) ਜੇਕਰ ਬਿਲਡਿੰਗ ਵਿਚ ਕਿਸੇ ਕਿਸਮ ਦੀ ਤਰੇੜ ਆ ਜਾਦੀ ਹੈ ਤਾਂ ਉਸ ਜਗ੍ਹਾ ਨੂੰ ਤੁਰੰਤ ਖਾਲੀ ਕੀਤਾ ਜਾਵੇ ਤੇ ਉਸ ਦੀ ਤੁਰੰਤ ਰਿਪੇਅਰ ਕਰਵਾਈ ਜਾਵੇ ।
- 3) ਕਿਸੇ ਕਿਸਮ ਦੀ ਉਸਾਰੀ ਵਿਚ ਵਰਤੇ ਗਏ ਮਟੀਰੀਅਲ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ । ਆਪ ਵਲੋਂ ਨੱਥੀ ਨਕਸ਼ੇ ਤੋਂ ਇਲਾਵਾ ਜੇਕਰ ਆਪ ਵਲੋਂ ਵਾਧੂ ਉਸਾਰੀ ਕਰਨੀ ਹੋਵੇ ਤਾਂ ਉਸ ਦੀ ਮੰਨਜ਼ੂਰੀ ਮਹਿਕਮੇ ਵਲੋਂ ਲਈ ਜਾਵੇਗੀ ।
- 4) ਡਾਇਰੈਕਟਰ ਜਨਰਲ ਸਕੂਲ ਸਿੱਖਿਆ ਵਿਭਾਗ ਪੰਜਾਬ ਅਤੇ ਸਟੇਟ ਪ੍ਰੋਜੈਕਟ ਸਰਵ ਸਿੱਖਿਆ ਅਭਿਆਨ ਦੇ ਪੱਤਰ ਨੰਬਰ 75444 ਮਿਤੀ 06-11-2009 ਮੁਤਾਬਿਕ ਸਕੂਲ ਵਿਚ ਅੱਗ ਬੁਝਾਓ ਯੰਤਰ ਠੀਕ ਹਾਲਤ ਵਿਚ ਰੱਖੇ ਜਾਣ । ਕਿਸੇ ਵੀ ਅਣਸੁਖਾਵੀ ਘਟਨਾ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ ।
- 5) ਅਗਲੇ ਸਾਲ 2027-28 ਦੀ ਇੰਨਸਪੈਕਸ਼ਨ ਕਰਾਉਣੀ ਯਕੀਨੀ ਬਣਾਈ ਜਾਵੇ ।

ਨੱਥੀ ਸਰਟੀਫਿਕੇਟ,

ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ. ਭ.ਮ. ਸਾਖਾ,
ਮੋਗਾ ।


Principal
Bhai Roop Chand Convent School
Samadh Bhai (Moga)
Affiliation No. (1631138)
School Code (21129)


Chairman
Bhai Roop Chand Convent School
Samadh Bhai (Moga)
Affi. No. 1631138 (School Code 21129)

**PROFORMA FOR SAFETY OF SCHOOL BUILDING
PART-I**

(To be filled by the Head of School / Institute)

- 1) Name of the School **BHAI ROOP CHAND CONVENT SCHOOL**
- 2) Location . **PHULLE WALA ROAD, SAMADH BHAI (MOGA)**
- 3) Plot Area. **1,08,900 Square Feet (2.5 Acres)**
- 4) Plinth Area. **5425 Square mtr.**
- 5) Number of storey's **GROUND FLOOR & FIRST FLOOR**
- 6) Year of construction of Building **2015**
- 7) If the building has been constructed under the Supervision of the qualified Engineer, the following details may be given:-

- a) Name of the Engineer with Qualification. :
- b) Address of Engineer. :
- c) Set of structural drawing used in the construction , Available. :
- d) Name & address of Architect with qualification :

- 8) Whether the building has been constructed for the Purpose school : **Yes / No**
Residential purpose and converted for use as a school : **Yes / No**

- 9) Material used for Roof.
 - a) R.C.C slab/ R.B.C Slabs : **Yes / No**
 - b) R.S. Joist & Battens. : **Yes / No**
 - c) Wooden Joist & Battens : **Yes / No.**

- 10) Material used for walls .
 - a) Mud Mortar. : **Yes / No**
 - b) Cement Mortar. : **Yes / No**
 - c) Lime Mortar. : **Yes / No**

- 11) Flooring .
 - a) Conglomerate : **Yes / No**
 - b) Terrazzo. : **Yes / No**
 - c) Brick Paving : **Yes / No**

- 12) A detailed drawing indicating dimension of Room Alongwith size and location of doors and windows (attached).

- 13) For Fire Safety .
 - a) Weather the width of the staircase is 1.5 Mtr . : **Yes / No**
 - b) Weather portable fire exiting. : **Yes / No**
 - c) Weather School building is free from inflammable & toxic material : **Yes / No**
 - d) Weather Cooking of food is done at a safe place : **Yes / No**
 - e) Weather any thatch of combustibile material as been Used. : **Yes / No**



Principal
Bhai Roop Chand Convent School
Samadh Bhai (Moga)
Affiliation No. (1631138)
School Code (21129)


Chairman
Bhai Roop Chand Convent School
Samadh Bhai (Moga)
Affi. No. 1631138 (School Code 21129)

14) Requirement for fire Protection Arrangements under NBC

Part -IV

- (For Building height Less than 15metre)
- | | | |
|--|---|---------------------|
| a) Weather house Real provided. | : | Yes / No |
| b) Weather down corner provided. | : | Yes / No |
| c) Weather automatic sprinkler provided. | : | Yes / No |
| d) Weather underground static water storage tank of Capacity 50,000Ltr.(It converted are excess 1600sqm) | : | Yes / No |
| e) Weather over head tank of capacity 10,000 Ltr. | : | Yes / No |
- Exists.(in case of house real) 20,000 Ltr.
- | | | |
|---|---|---------------------|
| f) Weather one electric and one diesel pump of 3 kg/ cum Pressure of capacity 1620 LPM.One electric pump of Capacity 180LPM exist near underground static tank. | : | Yes / No |
| g) Weather a pump 3 Kg /cum preasur& 450/500 LPM Exist near over head tank. | : | Yes / No |



School stamp

PART -II

(To be filled by the S.D.E for PWD (B&R) Department)

- a) I have visited the above mentioned school on date 15/05/26 a have visually inspected it from all angles of safety and found it fit for normal use as school building.
- b) In case any addition / alteration or expansion and modifications to this building is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by flood , or if there is settlement of walls/ foundation and sagging of roofs etc., immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) one year only (31/03/2027)


Sub Divisional Engineer
Municipal Sub Divisional Engineer
B & R Br. Moga

